

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 1126

Date : 11/09/2025

It is certified that an inspection team headed by Mr. Ramesh  
सं. कर्मचारी (Name of Officers  
with designation) from नगर निगम कोटा दक्षिण (Name of  
Department/Office) inspected the Sarvodaya Sr. Sec. School,  
IPC-17, RIICO Area Ranpur, Kota (Name & Address of  
the School) on 11/09/2025 and found that the Sarvodaya Sr.  
Sec. School (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 Year.

Signature with Seal :

Name

Designation



स्वास्थ्य निरीक्षक

नगर निगम कोटा दक्षिण

: रमेश

: सं. कर्मचारी

To

Sarvodaya Sr. Sec. School  
IPC-17, RIICO Area Ranpur  
Kota, Raj.

(Name & Address of the Institution)



**OFFICE OF THE SENIOR CHEMIST**  
**REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN**  
 PHED Campus, AKELGARH KOTA-324010



**Test Report**  
**(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)**

Disp. No. : 221

Dated : 20/5/26

Issued to:

**Principal**

Sarvodaya Sr. Sec. School, RIICO, Ranpur  
 Kota

District: Kota

Block/City: Kota

**Sample No. Collected by Lab**

Ref ID	23	Sample Code No.	PC-37 PB-29		
Reference : Letter No.	NM	Source :	RO		
Reference Date:	13.05.26	Source Location :	RIICO, Ranpur Kota		
Date of Receipt :	13.05.26	Habitation/Ward No. :	-		
Sample ID	33				
Name of Sample Collector:	Mujjaffar Ali	Village/Colony/Nagar :	-		
Designation of Sample Collector:	-	Gram Panchayat/City Area :	-		
Latitude of Location		Date of Collection :	13.05.26		
Longitude of Location		Start Date of Examination :	13.05.26		
Elevation of Location		End Date of Examination :	20.05.26		
Test Parameters	IS-10500:2012(RA 2023)		Sample Report No.		
	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:		
1	pH At Temp. 25 <sup>o</sup> C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	7.69
2	Turbidity	1.0	5.0	-	0.66
3	Total Alkalinity (as CaCO <sub>3</sub> ) mg/l	200	600	[IS 3025, P-23], 2023	230
4	Total Hardness (as CaCO <sub>3</sub> ) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2023)	180
5	Chloride (as Cl <sup>-</sup> ) mg/l	250	1000	[IS 3025, P-32], 2025	50
6	Nitrates (as NO <sub>3</sub> <sup>-</sup> ) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO3: 2023	10.0
7	Fluoride (as F <sup>-</sup> ) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2023)	0.189
8	Total Dissolved Solids (TDS) mg/l At 180 <sup>o</sup> C	500	2000	[IS 3025 P-16]: 2023 /APHA, Ed24, 2510-B] Cond.2023	358
9	Total Coliform (MPN/100ml)	Nil	Nil	-	NIL

**REPORT IS NOT VALID FOR JUDICIAL AND COMMERCIAL PURPOSE**

(\*ADL= Above detection limit; BDL= Below detection limit)

**Authorized Signatory**  
  
 Senior Chemist  
 PHED Reg.Lab. Kota

**NOTE:**

- This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- This test report reletes only to the samples/items submitted to the laboratory for test.
- This report is not valid for legal cases/legal purposes.
- Sample will be preserved only for 15 days from date of receipt.
- Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----